

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-0075:149 Page 1 of 1

**CATEGORY:** Control Unit (Non High-Rise)

**LISTEE:** Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford, CT 06472-1653  
Contact: \*Brian Reynolds (203) 484-1200 FAX (203) 484-7309

**DESIGN:** Model SENSISCAN 2000 fire alarm control unit. Inherently power limited, local, automatic, manual, auxiliary, remote station, proprietary and central station , releasing device, waterflow and sprinkler supervisory (local signaling only) service. Refer to listee's data sheet for additional detailed product description and operational considerations.

CPU-2000	Control Unit
VP-1F	Vented Dress Panel
CHS-4	Chassis
IZ-4, IZ-8	Zone Module
MPS-24, MPS-24B	Main Power Supply
MPS-24AF, MPS-24BF	
CAB-A2F, CAB-B2F	Cabinet
AVPS-24	Audio/Visual Power Supply Module
CR-4	Control Relay Module
CRE-4	Control Relay Expansion Module
IC-4, IC-4CC	Indicating Circuit Module
ICE-4	Indicating Circuit Expander Module
IZE-4	Indicating Zone Expander Module
TC-2, TC-4	Time Control Module
BP-1F	Battery Dress Panel
MP-1F	Module Dress Panel
71245, 71252	Resistor

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product designation, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control unit for use with separately listed electrically and functionally compatible initiating and indicating devices. This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

\*Rev. 06-14-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**